

## CORE SAMPLE DETAIL SUMMARY

**CLIENT**                    **A N Other**  
**Address**                   Avenue Road  
                                   Anytown

**Date**                                    9th June 2006

**PROJECT**  
 Core extraction & Measurement

**Project Manager**  
 Example only

### COREHARD LIMITED

4 Viewpoint Office Village  
 Babbage Road  
 Stevenage  
 HERTS  
 SG1 2EQ  
 Tel: 01438 225 102  
 Fax: 01438 213 721  
 E.mail: systems@corehard.com



**REP-0606-ANO-001**

Corehard Ref No.	Utility	Ref	Location	FW/CW	B/Course	S/Course	Total	P/F	Comments
060606/ANO/SR/001	ANO	12345	6 Chantry Close, Newtown	FW	0	49	49	F	Overall bound layer fails to achieve minimum layer value as per SROH A2.5.5b
060606/ANO/SR/002	ANO	12346	37 Newtown Road, Newtown	FW	0	71	71	P	Laid over Type 1 - Please refer to SROH - S8.2.2.c with regard to full depth 6mm in FW
060606/ANO/SR/003	ANO	12347	378 London Road, Newtown	CW	0	82	82	F	Laid over Type 1 - Overall depth fails to achieve minimum requirement of SROH - A2.5.5a
060606/ANO/SR/004	ANO	12348	Kenps Cottage, Newtown	FW	0	77	77	F	Laid over unclassified unbound material at depth 77mm
060606/ANO/SR/005	ANO	12349	High St, Newtown	CW	0	78	78	F	Laid over Type 1 - Overall depth fails to achieve minimum requirement of SROH - A2.5.5a
060606/ANO/SR/006	ANO	12350	O/s Cromer Hall, Newtown	CW	98	52	150	P	Laid over GSB Type 1 at depth 150mm
060606/ANO/SR/007	ANO	12351	121 Dale Rd, Newtown	FW	0	75	75	P	Laid over Type 1 - Please refer to SROH - S8.2.2.c with regard to full depth 6mm in FW
060606/ANO/SR/008	ANO	12352	18 Kirby Road, Newtown	FW	0	56	56	F	Laid over GSB Type 1 at depth 56mm - Overall bound fails requirement SROH A2.5.5b (60mm)
070606/ANO/SR/001	ANO	12353	Opp 73 Old Hill, Newtown	CW	0	90	90	F	Laid over Type 1 - Overall bound fails SROH A2.5.5a - 6mm CGSC not permitted in carriageway
070606/ANO/SR/002	ANO	12354	S/o 25 Houghton Road, Newtown	FW	0	79	79	P	Laid over Type 1 - Please refer to SROH - S8.2.2.c with regard to full depth 6mm in FW
080606/ANO/SR/001	ANO	12355	O/s 57 Oakwood Road, Newtown	CW	32	121	153	P	Laid over existing (On cutback) - Red denotes existing material measurement
080606/ANO/SR/002	ANO	12356	O/s 57 Oakwood Road, Newtown	FW	0	133	133	P	Laid over unclassified unbound material (possibly existing structure)
080606/ANO/SR/003	ANO	12357	O/s 8 Siverdale Road, Newtown	FW	19	19	38	F	Laid over existing (On cutback) - Red denotes existing material measurement SC fails SROH A2.5.3a
080606/ANO/SR/004	ANO	12358	O/s 16 The Birches, Newtown	CW	0	133	133	P	Laid over what appears to be CBM3 or lean mix material
080606/ANO/SR/005	ANO	12359	O/s 29 Windmill Lane, Newtown	FW	0	66	66	F	Laid over unclassified unbound or as dug material
080606/ANO/SR/006	ANO	12360	O/s 35 Springfield, Newtown	CW	38	16	54	F	Laid over existing (On cutback) - Red denotes existing material measurement SC fails SROH A2.5.3a
080606/ANO/SR/007	ANO	12361	80 Whitehouse Ave, Newtown	FW	0	66	66	P	Laid over what appears to be CBM3 or lean mix material
080606/ANO/SR/008	ANO	12362	O/s 5 Melrose Ave, Newtown	FW	0	34	34	P	Laid over concrete found at depth 34mm
080606/ANO/SR/009	ANO	12363	19 Chesterton Green, Newtown	FW	0	86	86	P	Laid over CBM 3 or lean mix - Please refer to SROH - S8.2.2.c with regard to full depth 6mm in FW
080606/ANO/SR/010	ANO	12364	46 Cowper Road, Newtown	FW	0	59	59	P	Laid over concrete found at depth 59mm
080606/ANO/SR/011	ANO	12365	31 Codmore Crescent, Newtown	FW	0	102	102	P	Laid over GSB Type 1 or similar granular graded material
080606/ANO/SR/012	ANO	12366	50-56 Laxley Road, Newtown	FW	0	65	65	F	Laid over unclassified unbound or as dug material (not believed to be over cutback)
080606/ANO/SR/013	ANO	12367	115 High St, Newtown	CW	79	52	131	F	Laid over existing HRABC (Over cutback). Very poor bond with no evidence of tack coat used
080606/ANO/SR/014	ANO	12368	64 Upper Hall Park, Newtown	FW	0	42	42	F	Laid over GSB Type 1 at depth 42mm - Overall bound fails requirement SROH A2.5.5b (60mm)

**key**     Overall thickness     Min Surface Course     Min Binder Course     Existing Road Surface     Single course

**Total Utility Cores**

**24**

**Pass**

**12**

